



America

# Attestation of Conformity

No. N8A 16 02 75386 030

**Holder of Certificate:** Shenzhen Kstar New Energy  
Company Limited

The 9th Floor, R&D Building  
Kstar Industrial Park, Guangming Hi-tech Industrial Zone  
518107 Shenzhen, Guangdong Province  
PEOPLE'S REPUBLIC OF CHINA


**Product:** Converter  
(PV grid-interactive inverter)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 64290160003701



**Date,** 2016-02-02

  
( Billy Qiu )



After preparation of the necessary technical documentation as well as the EU conformity declaration the required CE marking can be affixed on the product. That declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 2



America

**Attestation of Conformity**  
**No. N8A 16 02 75386 030**

**Model(s):** KSG-10K, KSG-12K, KSG-15K, KSG-17K, KSG-20K

<b>Parameters:</b>	Vmax PV (Vd.c.):	1000
	Isc PV (Ad.c):	15 x 2 (KSG-10K) 15 x 2 (KSG-12K) 23 x 2 (KSG-15K) 23 x 2 (KSG-17K) 23 x 2 (KSG-20K)
	Maximum continuous a.c. output current (A):	15 (KSG-10K) 18 (KSG-12K) 22 (KSG-15K) 25 (KSG-17K) 29 (KSG-20K)
	Maximum continuous a.c. output power (kW):	10 (KSG-10K) 12 (KSG-12K) 15 (KSG-15K) 17 (KSG-17K) 20 (KSG-20K)
	Nominal AC voltage (Va.c.):	3/N/PE 230/400
	Nominal a.c. output frequency (Hz):	50
	Protective class:	I
	IP code:	IP65

**Tested according to:** EN 62109-1:2010  
 EN 62109-2:2011